

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20251957
Address: 240 SW OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	Mitchell Schwarz	Partial	Wednesday, December 31, 2025

Informational:
1 Misc

- Fireline entering into building and roughly 10' out
- stub out from foundation for grease interceptor
- Grease interceptor installed
- Piping to and from interceptor across West side, (not connected to main)
- sanitary sewer stub out from foundation

Comments: