

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20254281
Address: 1933 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Wes Bears	Failed	Wednesday, December 31, 2025

Informational:

1	Misc	Garage portal frame ok to cover Back porch ceiling trusses are good and ok to cover
---	------	--

Corrective Action Required:

2	Misc
3	Miscellaneous Correction

1933
-fire block dryer vent through the floor in the basement
-strap the top plate on left side of the sliding door to deck

Corrective Action Required:

4	Miscellaneous Correction
---	-----------------------------

Comments: