



January 5, 2026

City of Lee's Summit
Development Services
220 SE Green Street
Lee's Summit, MO 64063

RE: Permit No. PRCOM20255330
Communications Tower for LS JOF
2 NE Tudor Road

To Whom It May Concern:

Please accept this letter as response to the plan review comments received 12/16/2025. Licensed contractor information will be provided prior to permit issuance.

Building Plan Review:

1. The FDP was approved on 12/2/2025.
2. Address Identification requirements acknowledged.
3. Hayden Tower plans, sheet A-4.0 revised to show the minimum frost protection depth of 36". Shelter drawings, sheet T-1, note added to show the minimum frost protection depth of 36".
4. Base plate drawings uploaded which include detail as to how tower will be anchored.
5. Final Geotech report signed and sealed by the engineer has been uploaded.
6. Sheet T-1.0 has been revised to reflect currently adopted code cycle years.

Please let me know if you need anything else to approve and issue this building permit.

Thank you,

A handwritten signature in blue ink, appearing to read 'Emily Roseberry'.

Emily Roseberry
Permitting Coordinator
SSC, Inc.
7171 W. 95th Street, Suite 600
Overland Park, KS 66212
O: 913-438-7700 ext. 2272
eroseberry@ssc.us.com