

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20245687

Address: 3260 NW PARAGON PKWY, LEES SUMMIT, MO 64081
3200 NW PARAGON PKWY, LEES SUMMIT,
MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	Shawn Hoffman	Partial	Monday, January 05, 2026

Corrective Action Required:

1	Misc	Under ground conduit for light poles
---	------	--------------------------------------

- North of driveway of retail phase 2, from East bridge to West bridge, 3' North of curbing. Light poles b.02- b.06

Comments: