

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20253665
Address: 2618 SW FARM FIELD RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Tyler Schreck	Partial	Wednesday, January 07, 2026

Corrective Action Required:

1	Misc	1/7/26 Tyler S. DW does not have enough aggregate in it. Need to have at least 4" of clean rock. Fail. 1/7/26 Tyler S. DW is formed and compacted with 4" of clean rock. Approve to pour.
---	------	--

Comments: