

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20253808  
Address: 2616 NE WOODLAND OAK DR, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Khanh Nguyen	Failed	Monday, January 12, 2026

Corrective Action Required:  
1 Misc Inspection of the garage portal walls, front and back patio ceiling only-OK to cover

Corrections:  
-Install longer strap for the west garage PFH wall  
-Submit footing inspection report  
-Erosion control

**Comments:**