

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE
PROSECUTED**

Permit #: PRRES20250233
Address: 2611 SW TRACKER LN, LEES SUMMIT, MO 64082

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control Inspection Residential	Tyler Schreck	Failed - Stop Work	Monday, January 12, 2026

Corrective Action Required
1 Misc

10/30/25 Tyler S. there is quite a bit of mud and some gravel in the curb at the entrance of site. this needs cleaned up before it flows into our storm water system.

10/31/25 Tyler S. field inlet in the back of property, the silt fence is down and needs put back up ASAP. Also there is dirt and rock in the curb at construction entrance and need cleaned up ASAP. Failure to do so quickly will result in a 2 day stop work order.

1/12/26 Tyler S. Failed erosion control. Mud has been tracked out into the street and down sw farmhouse rd. Need to get this cleaned up ASAP. No construction entrance established. Need to get rock down so that we dont track mud out into the streets. Silt fence has been down for a while now and needs to be set back up. Both rock pile and scrap wood pile is spilling out over silt fence. STOP WORK order will be issued today and will need to get this addressed before it can be lifted. FAIL.

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Comments: