

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20253369  
Address: 1130 SE RANCLAND ST, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control Inspection Residential</b>	Dustin Agcopra	Partial	Wednesday, January 14, 2026

Corrective Action Required:

1	DCM3 ESC REQUIRED 2 DAY	1-8-26 Dustin A, Restroom needs to be moved off of storm and placed in green space, Erosion must be maintained until vegetation. EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS. 1-14-26 Dustin A, restroom moved
---	----------------------------	---

**Comments:**