

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20241886
Address: 251 NE ALURA WAY, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pool Steel/Bonding - Commercial	Khanh Nguyen	Passed	Wednesday, January 14, 2026

Corrective Action Required:

1 Misc

Pool bonded:

-pool shell, 2 light niches, bonding jumpers for handrails and perimeter bonding, perimeter surface, ladder, handrail, ADA lift, jumper to equipments location

Comments: