

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20253531
Address: 1451 SE BAILEY FARMS PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|------------------|----------|-------------------------------|
| Underground Plumbing Inspection - Commercial | Mitchell Schwarz | Partial | Thursday, January 08, 2026 |

Informational:

1 Misc

The following areas inspected
Plumbing from pump room to pool
Plumbing in pool okay to cover
Underground pvc for csst gasline inspected (still need to test pressure of csst
and seal ends of pvc)

Comments: