

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20253402  
Address: 2230 SW CROWN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                | Inspector:         | Outcome: | Date:                       |
|----------------------------|--------------------|----------|-----------------------------|
| <b>Sidewalk Inspection</b> | Patrick Schonfeldt | Partial  | Wednesday, January 14, 2026 |

Informational:  
1 Misc 1/14/26 PS SW pre pour, forms in place and aggregate compacted, approved to pour. Due to expected freezing temps advised contractor to cover concrete with blankets to protect from freezing 3 days post pour

**Comments:**