



- Silt Fence (APWA ESC-03)
- Inlet/Outlet Protection (APWA ESC-06, ESC-07, & ESC-14 or Approved Equal)



Proposed 4" Conduit Profile



- GENERAL NOTES:**
- CONTRACTOR TO MAINTAIN 41" DEPTH UNLESS OTHERWISE STATED
 - CONTRACTOR SHALL PROTECT ALL EXISTING STORM DRAINAGE LINES AND STRUCTURES WITHIN THE PROJECT LIMITS. NO EXISTING STORM FACILITIES SHALL BE REMOVED OR DISTURBED. IF ANY EXISTING STORM LINE OR STRUCTURE IS DAMAGED OR DISTURBED DURING CONSTRUCTION, CONTRACTOR SHALL RESTORE IT TO ORIGINAL CONDITION.
 - EXISTING SANITARY SEWER SHOWN IS BASED ON LIMITED RECORD INFORMATION AND MAY NOT REFLECT ACTUAL FIELD CONDITIONS. CONTRACTOR SHALL VERIFY THE PRECISE DEPTH AND LOCATION OF ALL SANITARY SEWER LINES PRIOR TO COMMENCING WORK. CONTRACTOR ASSUMES FOR ANY/ALL DAMAGE RESULTING FROM FAILURE TO VERIFY ANY EXISTING UTILITIES.

NO.	BY	DATE	REVISION



ig **Consult Inc**
engineers planners

1533 Locust Street, Kansas City, Missouri 64108
CORPORATE LICENSE NO. E201000573 (MO.) / E-1736 (KS.) / LS 2019005467

3-PHASE POWER CONDUIT PLAN

MIDWEST AVIONICS
CITY OF LEE'S SUMMIT, JACKSON COUNTY, MISSOURI

X-REF NO. 25.075b	1	SHEET OF	4
DRAWING NO. 25.075			
DATE December 17, 2025			
JOB NO. 25.075			

IF THIS IS NOT A BLUE INK SEAL AND THE SIGNATURE IN BLUE INK, THE PLAN IS A COPY AND MAY CONTAIN UNAUTHORIZED ALTERATIONS. THE CERTIFICATION CONTAINED ON THIS DOCUMENT SHALL NOT APPLY TO ANY COPIES.

FILE LOCATION: G:\ISSUED DRAWINGS\PROJECTS\17-2025\20250724-001-LEE'S SUMMIT AIRPORT HANGER\WORK\CONDUIT_PLAN_17-2025-0023_PHASE_DRAWING.PLT
PLOT DATE: 12/17/2025 10:08 AM BY: ZACK VANDER

