



FIRE DEPARTMENT

Prevention Division
(816)969-1300

PLANS REVIEW CONDITIONS

Permit No: PRCOM20255581 Date: January 15, 2026
Project Title: COSTCO WHOLESale WAREHOUSE Applicant:
Location: 10 SE OLDHAM PKWY, LEES SUMMIT, MO 6408120 SE <NO CONTACT NAME AVAILABLE>
OLDHAM PKWY, LEES SUMMIT, MO 64081 <NO CONTACT INFORMATION AVAILABLE>
Type of Work:
Occupancy Group: M
Description: COSTCO WHOLESale WAREHOUSE - ONE STORY MECHANICAL BUILDING FOR RETAIL USE, HIGH PILE STORAGE, FOOD PREPERATION, AND REFRIGERATED GOODS
MG2 CORPORATION P.C.
1101 SECOND AVE. SUITE 100
SEATTLE , WA 98101
Primary: (206) 962-6500
store - 10 SE Oldham Pkwy
Gas - 20 SE Oldham Pkwy (permit not yet created)
Construction Type: Type VB (Unprotected)
Map Page:

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Craig Hill

Rejected

1. Fire sprinkler flow calculations have not been provided.

Action Required: Provide Flow calculations for the sprinkler system.

2. Ball drip not shown on the FDC

Action Required: Provide ball drip on FDC pipe.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.