



FIRE DEPARTMENT

**Prevention Division
(816)969-1300**

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20255581	Date:	January 15, 2026
Project Title:	COSTCO WHOLESale WAREHOUSE	Applicant:	
Location:	10 SE OLDHAM PKWY, LEES SUMMIT, MO 6408120 SE OLDHAM PKWY, LEES SUMMIT, MO 64081		<NO CONTACT NAME AVAILABLE> <NO CONTACT INFORMATION AVAILABLE>
Type of Work:			
Occupancy Group:	M		
Description:	COSTCO WHOLESale WAREHOUSE - ONE STORY MECHAN TILE BUILDING FOR RETAIL USE, HIGH PILE STORAGE, FOOD PREPERATION, AND REFRIGERATED GOODS	MG2 CORPORATION P.C. 1101 SECOND AVE. SUITE 100 SEATTLE , WA 98101	
store -	10 SE Oldham Pkwy	FORT WAYNE MATADOR INC 4900 E DUBLIN GRANVILLE RD COLUMBUS, OH	
Gas -	20 SE Oldham Pkwy (permit not yet created)		
Construction Type:	Type VB (Unprotected)		
Map Page:		Primary:	

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Craig Hill

Rejected

1. Fire sprinkler flow calculations have not been provided.

Action Required: Provide Flow calculations for the sprinkler system.

2. Ball drip not shown on the FDC

Action Required: Provide ball drip on FDC pipe.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.