

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOMCOM20240778
Address: 500 SW LONGVIEW RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Shawn Hoffman	Failed	Thursday, January 15, 2026

Corrective Action Required:

- | | | |
|---|------|------------------------------------------------------------------|
| 1 | Misc | - Seal all exterior penetrations |
| | | - light missing bulb outside east door of storage room HT-6 |
| | | - electrical panels in AI 116E for L1B3 side 43-84 provide blank |
| | | - complete items from all other departments |

OK to bring in equipment and furniture. This is not an Occupancy

Comments: