

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20254158  
Address: 2008 NE BLUESTONE DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Khanh Nguyen	Failed	Friday, January 16, 2026

Corrective Action Required:

- |   |      |   |
|---|------|---|
| 1 | Misc | -Provide attic access to roof space above garage                  |
|   |      | -Fb fireplace space from joist space                              |
|   |      | -Provide joist hangers above front office                         |
|   |      | -Screw the service main bonding screw all the way in              |
|   |      | -Bonding gas piping   |
|   |      | -Provide support for lvl ridge at bedroom 4                       |
|   |      | -Provide support for roof-support 2x10 at bathroom/bedroom 4 wall |
|   |      | -Strap wall top plates lapped less than 24" at shared bathroom    |
|   |      | -Fb space adjacent to tub from roof                               |
|   |      | -Protect dryer duct with min 16 gauge plate                       |

\*\*OK TO INSULATE

**Comments:**