

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRESRES20253206

Address: 231 NW ORCHARD CT, LEES SUMMIT, MO 64063229 NW ORCHARD CT, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Friday, January 16, 2026

Informational:
1 Misc Exterior sheathing ok to cover
Attic framing ok to cover

Corrective Action Required:
2 Misc -in the attic space of demise wall, tape and mud all gapes at joist on both sides

Comments: