

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE
PROSECUTED**

Permit #: PRCOM20245463
Address: 2701 NE MCBAINE DR, Unit:IR, LEES SUMMIT, MO 64064
2701 NE MCBAINE DR, LEES SUMMIT, MO 64064

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control Inspection	Nick Scott	Failed - Stop Work	Tuesday, January 20, 2026

Informational
1 Misc

Plastic Surgun Construction
7-25-25 NS Site visited and it appears that silt fence has been knocked down and needs to be replaced and put back up.
Failed
8-5-25 NS Site visited, and it appears that erosion control is correct. but grass has grown, and no signs of mud/ lose dirt so will not need to be fixed until construction starts again.
8-19-25 NS Site visited and it appears that no erosion control is working properly. grass has fully grown back and it appears some fence is down but would create more mud if the fence was fixed.
8-27-25 NS Site visited today and I do not see any problems with erosion control
10-13-25 NS. Site visited and it appears that ESC is in good working order.
10-25-25 NS Site visited and it appears that more construction is starting up and that the outside ESC has fallen down and needs

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

to be fixed when weather allows.

10-29-25 NS Site visited and it appears that ECV is not in compliance.

11-11-25 NS Site visited and no work has been done on ECV.

12-12-25 NS Site visited and it appears no work has been done on ECV.

1-8-26 NS Site visited and it appears that ESV has not been updated or fixed. Failed

Comments: