

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20244903  
Address: 2620 NE WOODLAND OAK DR, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Khanh Nguyen	Failed	Wednesday, January 21, 2026

Corrective Action Required:

- |   |      |   |
|---|------|---|
| 1 | Misc | -Provide access to pressure sewer shutoff valve **provide missing cover   |
|   |      | -Seal exterior wall penetration (irrigation pipe and sump pump discharge) |
|   |      | -Provide AFCI protection for fireplace outlet                             |

**Comments:**