



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20114350, Building Permit - Commercial  
Address: 690 NW BLUE PKWY, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Electrical Inspection - Commercial</b>	John Borns	Passed	Tuesday, May 01, 2012

**Comments: OK TO COVER WHEN READY UNDER-SLAB ELECTRICAL CONDUIT**