

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20244682  
Address: 19 NE SYCAMORE ST, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Robb Popp	Failed	Wednesday, January 21, 2026

Corrective Action Required:  
1 THIRD FLOOR -RC to be max 16" oc  
-Support ends of all RC  
-Install any missing screws

Corrective Action Required:

2 SECOND FLOOR

Corrective Action Required:

3 FIRST FLOOR

**Comments:**