

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20245749
Address: 2524 NE WOODLAND OAK CIR, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Failed	Wednesday, January 21, 2026

Corrective Action Required:

1	Misc	-Provide kitchen countertops receptacles per code **pop-up receptacles only rated for 15 amp
		-Complete upper and lower deck
		**Support the stair landing. Landing support rims attachments to post and cantilevered beam seem inadequate

Comments: