

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20253864
Address: 3801 SW LONGVIEW RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Piers/Caissons Inspection - Commercial	Shawn Hoffman	Failed	Thursday, January 22, 2026

Corrective Action Required:
1 Miscellaneous Correction - Upload light pole base detail to permit.

Informational:
2 Misc Piers Approved:
6 Pers for light poles in middle of South courts.

Corrective Action Required:
3 Misc 12 light pole bases, 4 around shade structure and 4 in west side and 4 on East side of court's Approved

Corrective Action Required:
4 Miscellaneous Correction - Light pole bases North on sidewalk not inspected and not on plans.

Comments: