

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20250029  
Address: 667 SE WOOD LN, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Thursday, January 22, 2026

Corrective Action Required:  
2 Misc

- seal bottom plate penetrations at primary bath
- Land NM electrical outside bed 3
- secure electrical in wall bed 2
- missing nails in hanger above 1/2 bath
- missing hangers at bottom of stairs joist above
- support dwv at bottom of stairs

**Comments:**