

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20251416

Address: 623 SE LINDBERG LN, LEES SUMMIT, MO 64063625 SE LINDBERG LN, LEES SUMMIT, MO 64063627
SE LINDBERG LN, LEES SUMMIT, MO 64063621 SE LINDBERG LN, LEES SUMMIT, MO
64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Service Inspection	Dustin Agcopra	Failed	Thursday, January 22, 2026

Corrective Action Required:

1	Misc	10-16-25 Pex is to shallow. Will need lowered
		1-22-26 Dustin A, Water line was buried without an inspection

Comments: