CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20253973
Address: 2038 SW HARVEST MOON LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Drew Fischer	Failed	Thursday, January 22, 2026

Informational:

1	Misc	Portal frame ok to cover

Corrective Action Required:

2	Misc	2038 SW Harvest Moon - Security blocking needed at rear door - Add straps to plumbing vent pipes throughout - Seal penetration on back master wall to right of window top plate - Add stud shoes in master closet at plumbing vent pipes - Seal penetrations in top plate in front bedroom - Address missing joist hangers and missing nails in hanger at bottom of steps - Bolts missing in basement posts - Fire block top plate cut out on front wall of front basement bedroom -

Comments: