

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20251400

Address: 627 SE GOLDEN LN, LEES SUMMIT, MO 64063629 SE GOLDEN LN, LEES SUMMIT, MO 64063631 SE
GOLDEN LN, LEES SUMMIT, MO 64063625 SE GOLDEN LN, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--------------------------------------|------------------|----------|-------------------------------|
| Electrical Service Inspection | Mitchell Schwarz | Failed | Thursday, January 22, 2026 |

Corrective Action Required:

| | | |
|---|------|--|
| 1 | Misc | -no more than one conductor per lug in panel -copper main bonding jumper shall be minimum #4 -remove all bonding screws past main disconnect |
|---|------|--|

Comments: