

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20244682  
Address: 19 NE SYCAMORE ST, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	Robb Popp	Partial	Tuesday, January 27, 2026

Corrective Action Required:

1	FIRST FLOOR	OK: -Pre-rock for long walls adjacent to tubs for all units
2	SECOND FLOOR	-Pre-rock for long walls adjacent to tubs for all units
3	THIRD FLOOR	Complete

**Comments:**