

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250037
Address: 647 SE WOOD LN, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Wednesday, January 28, 2026

Corrective Action Required:

2 Misc

- fireblock wall space into garage furr down
- seal penetrations in floor of primary bath
- plumbing protection shall cover and extend 2" below top plate throughout 2nd floor
- protect electrical in wall N Laundry room wall closer than 1 1/4" to face
- fireblock top of furr out wall in bath 2
- protect electrical 2nd floor bath E wall closer than 1 1/4" to face
- electrical spacing to be to E3901.2 see primary bedroom and dining room
- seal plate penetrations at 2nd story stairs and mechanical at stairs and under stairs

Comments: