


**Roof Truss Layout**  
Scale: 3/16" = 1'

HANGER SCHEDULE	Quantity
● LUS24	14
● LUS26	1
● HUS26	14
▲ HHUS26-2	0
▲ HGUS26-2	0
▲ HGUS28-3	0
■ LTHJA26	4
■ TJC37	5
■ TJC57	0
▲ HTS20	0

Triangle denotes the left end of the Truss as it appears on the Engineered Drawings provided.



Unless otherwise specified by Engineer Of Record, Wheeler Lumber, LLC recommends an uplift connection at each bearing point per the following:

# of Uplift	Connector
0 - 495:	(1) H2.5A
495 - 990:	(2) H2.5A
990 - 1245:	(1) HTS20

Installation per Simpson Strong-Tie guidelines.

For Reactions greater than 1245#, refer to EOR.

**RELEASE FOR CONSTRUCTION  
AS NOTED ON PLANS REVIEW  
DEVELOPMENT SERVICES  
LEE'S SUMMIT, MISSOURI  
01/28/2026 4:59:53**

EVERSTEAD  
SHOP DRAWINGS/SUBMITTAL REVIEW

SUBMITTAL WAS REVIEWED FOR DESIGN CONFORMITY AND GENERAL CONFORMANCE TO CONTRACT DOCUMENTS ONLY. THE CONTRACTOR IS RESPONSIBLE FOR CONFIRMING AND CORRELATING DIMENSIONS AT JOBSITE FOR TOLERANCE, CLEARANCE, QUANTITIES, FABRICATION, COORDINATION OF HIS OR HER WORK WITH OTHER TRADES, AND FULL COMPLIANCE WITH CONTRACT DOCUMENTS.

STATUS:  
**APPROVED AS NOTED**  
01/08/2026  
REVIEWED BY:  
**H CJ**

ENGINEER, EVERSTEAD ENGINEERING & DESIGN LLC.

TRUSS LAYOUT APPROVED FOR THE ADDRESS LISTED

Customer	Job Name	Job Site Address	City, State	Designer	Job #
Avital Homes	122 Reserve at Stoney Creek - Avalon Contemporary	1925 SW Hightown Dr	Lee's Summit MO	Chance Lickelg	785-746-4095

Customer	Job Name	Job Site Address	City, State	Designer	Job #
Avital Homes	122 Reserve at Stoney Creek - Avalon Contemporary	1925 SW Hightown Dr	Lee's Summit MO	Chance Lickelg	785-746-4095

THIS IS A TRUSS PLACEMENT DIAGRAM ONLY. THESE TRUSSES ARE DESIGNED AS INDIVIDUAL BUILDING COMPONENTS TO BE INCORPORATED INTO THE BUILDING DESIGN AT THE SPECIFICATION OF THE BUILDING DESIGNER. SEE INDIVIDUAL DESIGN SHEETS FOR EACH TRUSS DESIGN IDENTIFIED ON THE PLACEMENT DRAWING. THE BUILDING DESIGNER IS RESPONSIBLE FOR TEMPORARY AND PERMANENT BRACING OF THE TRUSSES TO BE INSTALLED. THE TRUSS DESIGNER'S RESPONSIBILITY IS LIMITED TO THE DESIGN OF THE TRUSSES AND THE BRACING OF THE WALLS AND COLUMNS TO INSURE AGAINST CHANGES THAT WILL RESULT IN EXTRA CHARGES TO YOU. "BRACING OF WOOD TRUSSES" AVAILABLE FROM THE TRUSS INSTITUTE, 583 DORRIS DRIVE, MADISON, WI 53179.

THIS LAYOUT IS THE SOLE SOURCE FOR FABRICATION OF TRUSSES AND VOIDS ALL PREVIOUS ARCHITECTURAL OR OTHER TRUSS LAYOUTS. REVIEW AND APPROVAL OF THIS LAYOUT MUST BE RECEIVED BEFORE ANY TRUSSES WILL BE BUILT. VERIFY ALL CONDITIONS TO INSURE AGAINST CHANGES THAT WILL RESULT IN EXTRA CHARGES TO YOU.

Approved By: \_\_\_\_\_ Date: \_\_\_\_\_

**Wheeler Lumber**  
1959 Old Hwy 50 NE  
Waverly, KS 66871

