

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20255258
Address: 624 NE MAGUIRE BLVD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|--------------|-------------------|----------------------------|
| Occupancy Inspection - Codes Commercial | Khanh Nguyen | Ready for Temp CO | Thursday, January 29, 2026 |

Corrective Action Required:

| | | |
|---|------|--|
| 1 | Misc | -Provide alternative to the required drinking fountain |
| | | -Partition walls were not inspected by city |
| | | -Label wall heater and water heater breakers |

Comments: