

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20255257
Address: 616 NE MAGUIRE BLVD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Khanh Nguyen	Ready for Temp CO	Thursday, January 29, 2026

Corrective Action Required:

- | | | |
|---|------|--|
| 1 | Misc | -Provide alternative to the required drinking fountain |
| | | -Partition walls were not inspected by city |
| | | -The water closet lever must be on the approach side of the bowl |
| | | -Label wall heater and water heater breakers |

Comments: