

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRCOM20255257
Address: 616 NE MAGUIRE BLVD, LEES SUMMIT, MO 64064
Inspected On: Thursday, January 29, 2026
Inspected By:
Expiration Date:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Khanh Nguyen	Ready for Temp CO	Thursday, January 29, 2026

Corrective Action Required:

- | | | |
|---|------|--|
| 1 | Misc | -Provide alternative to the required drinking fountain |
| | | -Partition walls were not inspected by city |
| | | -The water closet lever must be on the approach side of the bowl |
| | | -Label wall heater and water heater breakers |

Comments: