

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20253531  
Address: 1451 SE BAILEY FARMS PKWY, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control Inspection</b>	Dustin Agcopra	Partial	Friday, January 30, 2026

Corrective Action Required:

1	Misc	10-14-25 Dustin A, Erosion Control Required! The whole subdivision has allot of trash strung out through all the properties. All the trash needs to be cleaned withing 2 business days to prevent a STOP WORK being applied 10-16-25 Dustin a, Most of the trash is picked up, what is left i talked to colter and he said he wuld get it taken care of, 10-30-25 Dustin A, Erosion control is in place at this time 11-21-25 Dustin A, silt fence is down in some areas along sw bailey farms prkway 12-10-25 Dustin A, Silt fence is still down, Sidewalk needs to be cleaned. Road is covered in mud. Please fix this in 2 business days (12-12) to prevent a stop work order issued. 1-14-26 Dustin A, Esc is in place 1-30-26 Dustin A, Erosion control is in place. Site needs a concrete washout due to the ones in subdivision being removed .
---	------	--

Comments: