



**CITY OF LEE'S SUMMIT**  
**CODES ADMINISTRATION**

220 SE GREEN ST.  
P.O. BOX 1600

**PHONE:**  
816-969-1200

**FAX:**  
816-969-1201

# Temporary Certificate of Occupancy

---

**Permit #:** PRCOM20120225  
**Address:** 635 SW 2ND ST, LEES SUMMIT, MO 64063  
**Inspected On:** Friday, May 04, 2012  
**Inspected By:** John Borns  
**Expiration Date:** 5/10/2012 12:00:00 AM

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	John Borns	Temporary C of O	Friday, May 04, 2012

**Corrective Action Required:**

1 MISC ADA/ANSI: PADDING REQUIRED ON PIPING UNDER ACCESSIBLE RESTROOM LAVS/SINKS

**Corrective Action Required:**

2 MISC ADVISE TO CAP DISCONTINUOUS WATER PIPE AT UTILITY ROOM S.E.

**Corrective Action Required:**

3 MISC DUPLEX RECEPTACLES AT SUMP PUMP AND CLOTHES WASHER -- PROVIDE GFCI PROTECTION OR CHANGE TO DEDICATED SINGLE PLUG

**Corrective Action Required:**

4 MISC MAKE ELECTRICAL RECEPTACLES SOLID TO BOX @ CATERING ROOM EAST WALL

**Corrective Action Required:**

5 MISC AFFIX "NO SMOKING" SIGN TO PUBLIC ENTRY DOORS

Corrective Action Required:

6            MISC            PLACE 133 MAX OCCUPANCY SIGN PER FIRE DEPT

**Comments:**