

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250014
Address: 636 SE HIGHLAND PARK DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Not Ready	Monday, February 02, 2026

Informational:
1 Misc PFH at garage and front porch ok to cover
- mechanical room ok to Sheetrock
- front porch ceiling ok to cover

Corrective Action Required:
2 Misc Inspection denied no fire blocking done throughout. Complete fire blocking before calling for inspection

Comments: