

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20245900
Address: 2720 NE HAGAN RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	Khanh Nguyen	Failed	Monday, February 02, 2026

Corrective Action Required:

1	Misc	-Exterior wall grade beams from A/8.5 to 2/A to 2/G.2 to H/3.5; -3 column pads at 1/C,D,&E
---	------	---

2/2/26-Not ready for inspection

Comments: