

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20252507
Address: 250 NE ALURA WAY, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---------------------------------|--------------------|----------|---------------------------|
| Water Service Inspection | Patrick Schonfeldt | Partial | Monday, February 02, 2026 |

Informational:

| | | |
|---|------|---|
| 1 | Misc | 11-3-25 NS Site visited and it appears that fire line for building water main passed inspection. The pipe is only 3/4 of a stick. 1-27-26 NS site visited and it appears crews are going to start water line next week. 2-2-26 Contractor cut in 8" x 6" tee with gate valve post backflow vault for private hydrants |
|---|------|---|

Comments: