

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250037
Address: 647 SE WOOD LN, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Tuesday, February 03, 2026

Corrective Action Required:

1	Misc	-fireblock wall space into garage furr down (1/2" OSB not approved fireblock material) -protect electrical 2nd floor bath/bedroom closet E wall bath closer than 1 1/4" to face -seal top plate penetrations for electrical fixes in dining room -seal plate penetrations at 2nd story stairs first floor top plate and draft stop
---	------	---

Comments: