

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250038
Address: 655 SE WOOD LN, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Wes Bears	Failed	Wednesday, February 04, 2026

Informational:

1	Misc	-Portal frame inspection on front window and rear garage nailing okay -front sheathing nailing okay to cover -covered front porch okay to cover
---	------	---

Corrective Action Required:

2	Misc	-655 -tighten all anchor bolts -all pfh walls need double bottom plate -fire blocking in garage not approved 1/2" osb not approved -missing nails in 1/2 bath truss hanger -missing nails in truss hanger at stairs -land electrical in stairwell -address outlet spacing 6' 12' in primary bedroom and bed 3
---	------	--

Comments: