

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20253562
Address: 1134 SE RANCLAND ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Drew Fischer	Not Ready	Thursday, February 05, 2026

Corrective Action Required:

1	Misc	1134 SE Ranchland St _ -pay outstanding fees -security screws needed in front and basement door assemblies -water heater relief valve discharge pipe not to code p2804.6.1 (10) - splash blocks needed
---	------	--

Corrective Action Required:

2	Misc	Pay outstanding fees - Security screws needed in front and basement doors - Water heater discharge tube to be cut to length to meet code - splash blocks and sod needed
---	------	--

Comments: