

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20250074  
Address: 632 SE WOOD LN, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mitchell Schwarz	Failed	Thursday, February 05, 2026

Corrective Action Required:

1	Misc	632 -final grade -sod -splash blocks and sump pump discharge to extend 36" from foundation -secure A/c whips within 12" of disconnect -provide access to ufer ground connection -provide spark rings/ box extenders throughout entire unit where needed (leave face plates off in front of outlets where added) -laundry outlet to be GFCI protected -provide lock out for all hardwired appliances not in view of panel -provide floodlight at rear per Lees Summit chapter 7 security code -land sewer tracer wire
---	------	--

Comments: