

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250068
Address: 660 SE WOOD LN, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control Inspection Residential	Mitchell Schwarz	Partial	Friday, February 06, 2026

Corrective Action Required:

1 Misc Maintain overgrown vegetation being addressed under sub permit.

Corrective Action Required:

2 DCM3 ESC
REQUIRED 2 DAY Dustin A, silt fence is down . They have no construction entrance and tracking mud out EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS.

2-6-26 Dustin A, Issues have been corrected

Comments: