

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816) 969-1200 FAX (816) 969-1201

# STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE  
PROSECUTED**

---

**Permit #:** PRRES20254263  
**Address:** 1122 SE RANCLAND ST, LEES SUMMIT, MO 64081

---

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control Inspection Residential</b>	Dustin Agcopra	Failed - Stop Work	Monday, February 09, 2026

**Corrective Action Required**

1	DCM3 ESC REQUIRED 2 DAY	2-5-26 Dustin A, Erosion control needs to be repaired and restroom needs to be moved to a green space. EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS. 2-9-26 Dustin A, Restroom was moved to the driveway instead of a green space. ARestrooms cannot be placed on roads, sidewalks or or drives per city code. Fail. Stop work is issued.
---	----------------------------	---

**Comments:**