

DEVELOPMENT SERVICES

PLAN REVIEW CONDITIONS

February 09, 2026

M DESIGN
201 L STRETT
LAKE LOTAWANA, MO 64086

Permit No: PRCOM20260398
Project Title: CARRIER ENTERPRISES
Project Address: 644 NE MAGUIRE BLVD, LEES SUMMIT, MO 64064
Parcel Number: 52200021400000000
Location / Legal: LAKEWOOD BUSINESS PARK LOT 46---LOT 46
Description:
Type of Work: NEW TENANT FINISH
Occupancy Group: MERCANTILE
Description: TENANT FINISH FOR WAREHOUSE WITH SHOWROOM

Revisions Required

One or more departments have not approved the permit and the following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and upload the revised documents and /or additional information to the application through the online portal. Please contact the appropriate department regarding clarification of comments.

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

Licensed Contractors

Reviewed By: Joe Frogge

Approved

Building Plan Review

Reviewed By: Joe Frogge

Rejected

1. A one-time impact fee in the form of an excise tax must be collected before occupancy can be granted. Please be advised that additional application, review, and inspection fees do apply and additional information pertaining to this will be provided during that stage of your approval process.

Action required: Comment is informational. The fee will be \$18,001.50

2. 2018 IBC 1004.1 Design occupant load. In determining means of egress requirements, the number of occupants for whom means of egress facilities shall be provided shall be determined in accordance with this section.

Action required: Amend occupant load calc using 1:60 in Showroom 112.1.

3. 2018 IBC 1109.11 Seating at tables, counters and work surfaces. Where seating or standing space at fixed or built-in tables, counters or work surfaces is provided in accessible spaces, at least 5 percent of the seating and standing spaces, but not less than one, shall be accessible. (see code for exception)

DEVELOPMENT SERVICES

Action required: Amend design to show that counter top in showroom is maximum 34" tall.

4. ICC A117.1 Section 904.3 Sales and service counters and windows. Sales and service counters and windows shall comply with Section 904.3.1 and either 904.3.2 or 904.3.3. Where counters are provided, the accessible portion of the countertop shall extend the same depth as the public portion of the sales and service countertop provided for standing customers. (see code for exception) 904.3.1 Vertical barriers. At service windows or service counters, any vertical barrier between service personnel and customers shall be at a height of 43 inches maximum above the floor. (see code for exception regarding security glazing) 904.3.2 Parallel Approach. A portion of the public use side of the counter surface 36 inches minimum in length and 26 inches minimum and 36 inches maximum in height above the floor shall be provided. A clear floor space positioned for a parallel approach adjacent to the accessible counter shall be provided. The space between the accessible counter surface and any projecting objects above the accessible counter shall be 12 inches minimum. (see code for exception) 904.3.3 Forward Approach. A portion of the public use side of the counter surface 30 inches minimum in length and 36 inches maximum in height above the floor shall be provided. A clear floor space positioned for a forward approach to the accessible counter shall be provided. Knee and toe clearance complying with Section 306 shall be provided under the accessible counter. The space between the accessible counter surface and any projecting objects above the accessible counter shall be 12" minimum.

Action required: Comment is informational. If a point of sales counter is provide it must be accessible.

5. 2017 NEC Article 210.63 Heating, Air-Conditioning, and Refrigeration Equipment Outlet. A 125-volt, single-phase, 15- or 20-ampere-rated receptacle outlet shall be installed at an accessible location for the servicing of heating, air-conditioning, and refrigeration equipment. The receptacle shall be located on the same level and within 25 feet of the heating, air-conditioning, and refrigeration equipment. The receptacle outlet shall not be connected to the load side of the equipment disconnecting means.

Action required: Provide receptacle near condensing units.

Fire Plan Review

Reviewed By: Craig Hill

Approved with Conditions

1. 2018 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. .A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions.

Action Required: Provide deferred submittal for fire alarm system.

2. 2018 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

Action Required: Provide deferred submittal for fire protection system.

DEVELOPMENT SERVICES

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.