

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20243955
Address: 3141 SW SUMMIT VIEW TRL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Drew Fischer	Failed	Tuesday, February 10, 2026

Corrective Action Required:

1	Misc	3141 SW Summitview tel - Irrigation outlet and single fringe outlet in garage must be labeled non gfci - Sump outlet in basement must be labeled non gfci - Final sidewalk inspection needed - Obtain irrigation permit
---	------	---

Corrective Action Required:

2 Misc

Corrective Action Required:

3	Misc	3141 SW Summitview - Irrigation outlet and single fringe outlet in garage must be labeled non gfci - Sump outlet in basement must be labeled non gfci - Final sidewalk inspection needed
---	------	---

Comments: