

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20253808
Address: 2616 NE WOODLAND OAK DR, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Tuesday, February 10, 2026

Corrective Action Required:

1	Misc	-Nail siding to sill plates @6" oc
		-Add (3)2x4 support stud under LVL beam at pocket office/foyer wall **protect wirings
		-Nail hanger above foyer **west hanger near entry door not fully nailed
		-Secure upper column base to I beam flanges **just hammer the tabs down to flange

Comments: