

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20253261
Address: 2622 SW FARM FIELD RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Drew Fischer	Failed	Tuesday, February 10, 2026

Corrective Action Required:

1	Misc	Spark rings needed at kitchen tile backsplash - irrigation outlet needs labeled as non-gfci - sump must discharge 36" from foundation - tamper proof caps need on AC unit - handrail needed on deck stairs that is continuous for the full length of the flight, as per code R311.7.8.4 - irrigation permit needed
---	------	---

Comments: