

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20253930
Address: 2225 SW HEARTLAND CT, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Drew Fischer	Failed	Tuesday, February 10, 2026

Corrective Action Required:

1	Misc	Portal frame on front is covered, can not inspect nailing pattern. Portal frame on rear ok to cover
---	------	--

Corrective Action Required:

2	Misc	<ul style="list-style-type: none">- portal frame nailing pattern not approved at garage door, was covered at last inspection, new siding has been overlaid with no inspection of nailing pattern- Protect wiring within 6' of attic access- fire blocking needed at cutout in bottom plate, master bedroom/bath wall- add fire blocking at post beam connection in stairwell landing- bolts missing in posts in basement-
---	------	--

Comments: