

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20244682
Address: 19 NE SYCAMORE ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Robb Popp	Partial	Wednesday, February 11, 2026

Corrective Action Required:

1	FIRST FLOOR	OK: -Pre-rock for long walls adjacent to tubs for all units Throughout: Clubhouse not ready, units only Exterior riser room not inspected -Complete plumbing traps in joist space -Install angle brackets at end joists in breezeway both ends 102-complete SE cables, seal dead space at bath
---	-------------	---

Corrective Action Required:

2	SECOND FLOOR	-Pre-rock for long walls adjacent to tubs for all units Throughout: -Install angle brackets at end joists in breezeway both ends -Decks not inspected
---	--------------	--

Corrective Action Required:

3	THIRD FLOOR	Complete
---	-------------	----------

Comments:

